



**Kennebec Valley Community College  
92 Western Avenue  
Fairfield, ME 04937**

**Competitive Bid  
Request for Proposal  
Exterior Building Signage**

**Addendum II  
October 26, 2022**

**Question I- Email received October 7, 2022**

*Share the pictures of the Building where the Signs are installed and will be removed.*

**Reply I**

Carter Hal



Lunder Hall



Averill Hall



**Question II- Email received October 7, 2022**

*Share the picture of the Buildings where the new signs will be installed.*

**Reply II**

KENNEBEC VALLEY COMMUNITY COLLEGE IS AN EQUAL OPPORTUNITY/AFFIRMATIVE ACTION INSTITUTION AND EMPLOYER  
FOR MORE INFORMATION, PLEASE CONTACT (207) 453-5019

See photos in Reply I as locations are the same.

**Question III- Email received October 7, 2022**

*Advise the mounting method*

**Reply III**

Appropriate for the material of the building; Carter Hall is a painted steel beam and Averill Hall and Lunder Hall are brick.

**Question IV- Email received October 7, 2022**

*Size of the Lettering, Font etc details are missing. We need those as well.*

**Reply IV**

All fonts will be Times New Roman; to match existing lettering on campus.  
Averill Hall lettering is approximately 10” high. Lunder Hall- lettering is approximately 12” high. Carter Hall-lettering is approximately 8” high.

Final lettering sizes will need to be field verified by contracted vendor.